
USACE / NAVFAC / AFCEC / NASA UFGS-01 78 23 (August 2015)

Preparing Activity: NAVFAC Superseding
UFGS-01 78 23 (July 2006)

UNIFIED FACILITIES GUIDE SPECIFICATION

References are in agreement with UMRL dated October 2019

SECTION TABLE OF CONTENTS

DIVISION 01 - GENERAL REQUIREMENTS

SECTION 01 78 23

OPERATION AND MAINTENANCE DATA

08/15

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 OPERATION AND MAINTENANCE DATA
 - 1.3.1 Package Quality
 - 1.3.2 Package Content
 - 1.3.3 Changes to Submittals
 - 1.3.4 Commissioning Authority Review and Approval
- 1.4 O&M DATABASE
- 1.5 OPERATION AND MAINTENANCE MANUAL FILE FORMAT
 - 1.5.1 Organization
 - 1.5.2 CD or DVD Label and Disk Holder or Case
- 1.6 TYPES OF INFORMATION REQUIRED IN O&M DATA PACKAGES
 - 1.6.1 Operating Instructions
 - 1.6.1.1 Safety Precautions and Hazards
 - 1.6.1.2 Operator Prestart
 - 1.6.1.3 Startup, Shutdown, and Post-Shutdown Procedures
 - 1.6.1.4 Normal Operations
 - 1.6.1.5 Emergency Operations
 - 1.6.1.6 Operator Service Requirements
 - 1.6.1.7 Environmental Conditions
 - 1.6.1.8 Operating Log
 - 1.6.1.9 Additional Requirements for HVAC Control Systems
 - 1.6.2 Preventive Maintenance
 - 1.6.2.1 Lubrication Data
 - 1.6.2.2 Preventive Maintenance Plan, Schedule, and Procedures
 - 1.6.2.3 Cleaning Recommendations
 - 1.6.3 Repair
 - 1.6.3.1 Troubleshooting Guides and Diagnostic Techniques
 - 1.6.3.2 Wiring Diagrams and Control Diagrams
 - 1.6.3.3 Repair Procedures
 - 1.6.3.4 Removal and Replacement Instructions
 - 1.6.3.5 Spare Parts and Supply Lists
 - 1.6.3.6 Repair Work-Hours
 - 1.6.4 Real Property Equipment

- 1.6.5 Appendices
 - 1.6.5.1 Product Submittal Data
 - 1.6.5.2 Manufacturer's Instructions
 - 1.6.5.3 O&M Submittal Data
 - 1.6.5.4 Parts Identification
 - 1.6.5.5 Warranty Information
 - 1.6.5.6 Extended Warranty Information
 - 1.6.5.7 Personnel Training Requirements
 - 1.6.5.8 Testing Equipment and Special Tool Information
 - 1.6.5.9 Testing and Performance Data
 - 1.6.5.10 Field Test Reports
 - 1.6.5.11 Contractor Information
- 1.7 SCHEDULE OF OPERATION AND MAINTENANCE DATA PACKAGES
 - 1.7.1 Data Package 1
 - 1.7.2 Data Package 2
 - 1.7.3 Data Package 3
 - 1.7.4 Data Package 4
 - 1.7.5 Data Package 5

PART 2 PRODUCTS

PART 3 EXECUTION

- 3.1 TRAINING
 - 3.1.1 Training Plan
 - 3.1.2 Training Content
 - 3.1.3 Training Outline
 - 3.1.4 Training Video Recording
 - 3.1.5 Unresolved Questions from Attendees
 - 3.1.6 Validation of Training Completion
 - 3.1.7 Quality Control Coordination

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC / NASA UFGS-01 78 23 (August 2015)

Preparing Activity: NAVFAC Superseding
UFGS-01 78 23 (July 2006)

UNIFIED FACILITIES GUIDE SPECIFICATION

References are in agreement with UMRL dated October 2019

SECTION 01 78 23

OPERATION AND MAINTENANCE DATA 08/15

NOTE: This guide specification covers the requirements for Operation and Maintenance (O&M) data packages, manuals and training.

Use this section on all projects. In addition, use Specification Section 01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND MAINTENANCE SUPPORT INFORMATION (eOMSI) for projects within the threshold of NAVFAC ECB 2014-01 and others as requested by the local PW office. Consult the Administering Public Works Office on construction contracts to determine if Section 01 78 24.00 20 must also be used.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

NOTE: This specification contains tailoring for NAVY, ARMY, FACILITY DATA WORKBOOK, COMMISSIONING AUTHORITY, DESIGN-BID-BUILD, and DESIGN-BUILD.

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM E1971

(2005; R 2011) Standard Guide for
Stewardship for the Cleaning of Commercial
and Institutional Buildings

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office

(Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" following a submittal item indicates that the submittal is required for the Sustainability eNotebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING. Locate the "S" submittal under the SD number that best describes the submittal item.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

NOTE: For Navy DB projects, delete 01 33 00, SUBMITTAL PROCEDURES, and replace with Section 01 33 00.05 20, CONSTRUCTION SUBMITTAL PROCEDURES and Section 01 33 10.05 20, DESIGN SUBMITTAL PROCEDURES.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submittals with an "S" are for inclusion in the Sustainability eNotebook, in conformance with Section 01 33 29 SUSTAINABILITY REPORTING. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-10 Operation and Maintenance Data

O&M Database ; G[, [_____]]

Training Plan ; G[, [_____]]

Training Outline ; G[, [_____]]

Training Content ; G[, [_____]]

SD-11 Closeout Submittals

Training Video Recording ; G[, [_____]]

Validation of Training Completion ; G[, [_____]]

1.3 OPERATION AND MAINTENANCE DATA

NOTE: The provisions of this section apply to those items requiring operation and maintenance data by the technical sections and to those items being commissioned. The technical sections include a paragraph "SD-10 Operation and Maintenance Data,"

stating: "Submit Operation and Maintenance Data in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA, Data Package [1] [2] [3] [4] [5]." The O&M requirements specified herein may be supplemented by operation, maintenance, and repair requirements particular to certain equipment specified in the pertinent technical section.

Submit Operation and Maintenance (O&M) Data for the provided equipment, product, or system, defining the importance of system interactions, troubleshooting, and long-term preventive operation and maintenance. Compile, prepare, and aggregate O&M data to include clarifying and updating the original sequences of operation to as-built conditions. Organize and present information in sufficient detail to clearly explain O&M requirements at the system, equipment, component, and subassembly level. Include an index preceding each submittal. Submit in accordance with this section and Section 01 33 00 SUBMITTAL PROCEDURES.

1.3.1 Package Quality

Documents must be fully legible. Operation and Maintenance data must be consistent with the manufacturer's standard brochures, schematics, printed instructions, general operating procedures, and safety precautions.

1.3.2 Package Content

NOTE: Where commissioning is used in the project, choose bracketed item to specify which data package to use for items that have no data package specified in the technical section, and for items with data package 1 or 2 specified by default in the technical section.

Provide data package content in accordance with paragraph SCHEDULE OF OPERATION AND MAINTENANCE DATA PACKAGES. Comply with the data package requirements specified in the individual technical sections, including the content of the packages and addressing each product, component, and system designated for data package submission, except as follows. Use Data Package [3][4][5] for commissioned items without a specified data package requirement in the individual technical sections. Provide a Data Package [3][4][5] instead of Data Package 1 or 2, as specified in the individual technical section, for items that are commissioned.

1.3.3 Changes to Submittals

Provide manufacturer-originated changes or revisions to submitted data if a component of an item is so affected subsequent to acceptance of the O&M Data. Submit changes, additions, or revisions required by the Contracting Officer for final acceptance of submitted data within 30 calendar days of the notification of this change requirement.

1.3.4 Commissioning Authority Review and Approval

NOTE: Use this paragraph if a Commissioning Authority is used for the project.

Submit the commissioned systems and equipment submittals to the Commissioning Authority (CxA) to review for completeness and applicability. Obtain validation from the CxA that the systems and equipment provided meet the requirements of the Contract documents and design intent, particularly as they relate to functionality, energy performance, water performance, maintainability, sustainability, system cost, indoor environmental quality, and local environmental impacts. The CxA communicates deficiencies to the Contracting Officer. Submit the O&M manuals to the Contracting Officer upon a successful review of the corrections, and with the CxA recommendation for approval and acceptance of these O&M manuals. This work is in addition to the normal review procedures for O&M data.

[1.4 O&M DATABASE

**NOTE: Do not use this paragraph if Section
01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND
MAINTENANCE SUPPORT INFORMATION (eOMSI) is included
in the contract.**

Develop an editable, electronic spreadsheet based on the equipment in the Operation and Maintenance Manuals that contains the information required to start a preventive maintenance program. As a minimum, provide list of system equipment, location installed, warranty expiration date, manufacturer, model, and serial number.

]1.5 OPERATION AND MAINTENANCE MANUAL FILE FORMAT

Assemble data packages into electronic Operation and Maintenance Manuals. Assemble each manual into a composite electronically indexed file using the most current version of Adobe Acrobat or similar software capable of producing PDF file format. Provide compact disks (CD) or data digital versatile disk (DVD) as appropriate, so that each one contains operation, maintenance and record files, project record documents, and training videos. Include a complete electronically linked operation and maintenance directory.

1.5.1 Organization

Bookmark Product and Drawing Information documents using the current version of CSI Masterformat numbering system, and arrange submittals using the specification sections as a structure. Use CSI Masterformat and UFGS numbers along with descriptive bookmarked titles that explain the content of the information that is being bookmarked.

1.5.2 CD or DVD Label and Disk Holder or Case

Provide the following information on the disk label and disk holder or case:

- a. Building Number
- b. Project Title
- c. Activity and Location

- d. Construction Contract Number
- e. Prepared For: (Contracting Agency)
- f. Prepared By: (Name, title, phone number and email address)
- g. Include the disk content on the disk label
- h. Date
- i. Virus scanning program used

1.6 TYPES OF INFORMATION REQUIRED IN O&M DATA PACKAGES

NOTE: O&M Data needed for any product, system, or piece of equipment depends upon the complexity of that item. The types of O&M Data, defined below, are grouped into Data Packages in paragraph SCHEDULE OF OPERATION AND MAINTENANCE DATA PACKAGES. The Data Package numbers, in turn, appear in the technical guide specifications.

The following are a detailed description of the data package items listed in paragraph SCHEDULE OF OPERATION AND MAINTENANCE DATA PACKAGES.

1.6.1 Operating Instructions

Provide specific instructions, procedures, and illustrations for the following phases of operation for the installed model and features of each system:

1.6.1.1 Safety Precautions and Hazards

List personnel hazards and equipment or product safety precautions for operating conditions. List all residual hazards identified in the Activity Hazard Analysis provided under Section 01 35 26 GOVERNMENT SAFETY REQUIREMENTS. Provide recommended safeguards for each identified hazard.

1.6.1.2 Operator Prestart

Provide procedures required to install, set up, and prepare each system for use.

1.6.1.3 Startup, Shutdown, and Post-Shutdown Procedures

Provide narrative description for Startup, Shutdown and Post-shutdown operating procedures including the control sequence for each procedure.

1.6.1.4 Normal Operations

Provide Control Diagrams with data to explain operation and control of systems and specific equipment. Provide narrative description of Normal Operating Procedures.

1.6.1.5 Emergency Operations

Provide Emergency Procedures for equipment malfunctions to permit a short period of continued operation or to shut down the equipment to prevent further damage to systems and equipment. Provide Emergency Shutdown Instructions for fire, explosion, spills, or other foreseeable contingencies. Provide guidance and procedures for emergency operation of utility systems including required valve positions, valve locations and zones or portions of systems controlled.

1.6.1.6 Operator Service Requirements

Provide instructions for services to be performed by the operator such as lubrication, adjustment, inspection, and recording gauge readings.

1.6.1.7 Environmental Conditions

Provide a list of Environmental Conditions (temperature, humidity, and other relevant data) that are best suited for the operation of each product, component or system. Describe conditions under which the item equipment should not be allowed to run.

1.6.1.8 Operating Log

Provide forms, sample logs, and instructions for maintaining necessary operating records.

1.6.1.9 Additional Requirements for HVAC Control Systems

Provide Data Package 5 and the following for control systems:

- a. Narrative description on how to perform and apply functions, features, modes, and other operations, including unoccupied operation, seasonal changeover, manual operation, and alarms. Include detailed technical manual for programming and customizing control loops and algorithms.
- b. Full as-built sequence of operations.
- c. Copies of checkout tests and calibrations performed by the Contractor (not Cx tests).

NOTE: Include the following items d through g below, depending on the project scope.

- d. Full points list. Provide a listing of rooms with the following information for each room:

- (1) Floor
- (2) Room number
- (3) Room name
- (4) Air handler unit ID
- (5) Reference drawing number

- (6) Air terminal unit tag ID
- (7) Heating or cooling valve tag ID
- (8) Minimum cfm
- (9) Maximum cfm
- e. Full print out of all schedules and set points after testing and acceptance of the system.
- f. Full as-built print out of software program.
- g. Marking of system sensors and thermostats on the as-built floor plan and mechanical drawings with their control system designations.

1.6.2 Preventive Maintenance

Provide the following information for preventive and scheduled maintenance to minimize repairs for the installed model and features of each system. Include potential environmental and indoor air quality impacts of recommended maintenance procedures and materials.

1.6.2.1 Lubrication Data

Include the following preventive maintenance lubrication data, in addition to instructions for lubrication required under paragraph OPERATOR SERVICE REQUIREMENTS:

- a. A table showing recommended lubricants for specific temperature ranges and applications.
- b. Charts with a schematic diagram of the equipment showing lubrication points, recommended types and grades of lubricants, and capacities.
- c. A Lubrication Schedule showing service interval frequency.

1.6.2.2 Preventive Maintenance Plan, Schedule, and Procedures

Provide manufacturer's schedule for routine preventive maintenance, inspections, condition monitoring (predictive tests) and adjustments required to ensure proper and economical operation and to minimize repairs. Provide instructions stating when the systems should be retested. Provide manufacturer's projection of preventive maintenance work-hours on a daily, weekly, monthly, and annual basis including craft requirements by type of craft. For periodic calibrations, provide manufacturer's specified frequency and procedures for each separate operation.

- a. Define the anticipated time required to perform each of each test (work-hours), test apparatus, number of personnel identified by responsibility, and a testing validation procedure permitting the record operation capability requirements within the schedule. Provide a remarks column for the testing validation procedure referencing operating limits of time, pressure, temperature, volume, voltage, current, acceleration, velocity, alignment, calibration, adjustment, cleaning, or special system notes. Delineate procedures for preventive maintenance, inspection, adjustment, lubrication and cleaning necessary to minimize repairs.

- b. Repair requirements must inform operators how to check out, troubleshoot, repair, and replace components of the system. Include electrical and mechanical schematics and diagrams and diagnostic techniques necessary to enable operation and troubleshooting of the system after acceptance.

1.6.2.3 Cleaning Recommendations

NOTE: This paragraph is tailored to use on Navy projects only.

Provide environmentally preferable cleaning recommendations in accordance with **ASTM E1971**.

1.6.3 Repair

Provide manufacturer's recommended procedures and instructions for correcting problems and making repairs for the installed model and features of each system. Include potential environmental and indoor air quality impacts of recommended maintenance procedures and materials.

1.6.3.1 Troubleshooting Guides and Diagnostic Techniques

Provide step-by-step procedures to promptly isolate the cause of typical malfunctions. Describe clearly why the checkout is performed and what conditions are to be sought. Identify tests or inspections and test equipment required to determine whether parts and equipment may be reused or require replacement.

1.6.3.2 Wiring Diagrams and Control Diagrams

Provide point-to-point drawings of wiring and control circuits including factory-field interfaces. Provide a complete and accurate depiction of the actual job specific wiring and control work. On diagrams, number electrical and electronic wiring and pneumatic control tubing and the terminals for each type, identically to actual installation configuration and numbering.

1.6.3.3 Repair Procedures

Provide instructions and a list of tools required to repair or restore the product or equipment to proper condition or operating standards.

1.6.3.4 Removal and Replacement Instructions

Provide step-by-step procedures and a list of required tools and supplies for removal, replacement, disassembly, and assembly of components, assemblies, subassemblies, accessories, and attachments. Provide tolerances, dimensions, settings and adjustments required. Use a combination of text and illustrations.

1.6.3.5 Spare Parts and Supply Lists

Provide lists of spare parts and supplies required for repair to ensure continued service or operation without unreasonable delays. Special consideration is required for facilities at remote locations. List spare

parts and supplies that have a long lead-time to obtain.

1.6.3.6 Repair Work-Hours

Provide manufacturer's projection of repair work-hours including requirements by type of craft. Identify, and tabulate separately, repair that requires the equipment manufacturer to complete or to participate.

1.6.4 Real Property Equipment

NOTE: Do not use this paragraph for Navy projects.
If this information is required, use Section
01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND
MAINTENANCE SUPPORT. This paragraph is tailored for
Army use.

NOTE: This paragraph is intended to provide data on
equipment and materials incorporated in the
construction of the project that cannot readily be
determined after completion of construction. The
data is expected to be of value for future
maintenance, alteration, and repair work. The
designer should predetermine the items on which data
is required and list them in the DESCRIPTION column
of the following form. A typical list of items
would include such things as: roofing, insulation,
and special wall coverings. Delete paragraph if
none specified.

Provide a list of installed equipment furnished under this contract. Include all information usually listed on manufacturer's name plate. In the "EQUIPMENT-IN-PLACE LIST" include, as applicable, the following for each piece of equipment installed: description of item, location (by room number), model number, serial number, capacity, name and address of manufacturer, name and address of equipment supplier, condition, spare parts list, manufacturer's catalog, and warranty. Submit the final list [30][_____] days after transfer of the completed facility.

Key the designations to the related area depicted on the contract drawings. List the following data:

RECORD OF DESIGNATED EQUIPMENT AND MATERIALS DATA				
Description	Specification Section	Manufacturer and Catalog, Model, and Serial Number	Composition and Size	Where Used
[_____]				

1.6.5 Appendices

Provide information required below and information not specified in the preceding paragraphs but pertinent to the maintenance or operation of the

product or equipment. Include the following:

1.6.5.1 Product Submittal Data

Provide a copy of SD-03 Product Data submittals documented with the required approval.

1.6.5.2 Manufacturer's Instructions

Provide a copy of SD-08 Manufacturer's Instructions submittals documented with the required approval.

1.6.5.3 O&M Submittal Data

Provide a copy of SD-10 Operation and Maintenance Data submittals documented with the required approval.

1.6.5.4 Parts Identification

Provide identification and coverage for the parts of each component, assembly, subassembly, and accessory of the end items subject to replacement. Include special hardware requirements, such as requirement to use high-strength bolts and nuts. Identify parts by make, model, serial number, and source of supply to allow reordering without further identification. Provide clear and legible illustrations, drawings, and exploded views to enable easy identification of the items. When illustrations omit the part numbers and description, both the illustrations and separate listing must show the index, reference, or key number that will cross-reference the illustrated part to the listed part. Group the parts shown in the listings by components, assemblies, and subassemblies in accordance with the manufacturer's standard practice. Parts data may cover more than one model or series of equipment, components, assemblies, subassemblies, attachments, or accessories, such as typically shown in a master parts catalog.

1.6.5.5 Warranty Information

List and explain the various warranties and clearly identify the servicing and technical precautions prescribed by the manufacturers or contract documents in order to keep warranties in force. Include warranty information for primary components of the system. Provide copies of warranties required by Section 01 78 00 CLOSEOUT SUBMITTALS.

1.6.5.6 Extended Warranty Information

List all warranties for products, equipment, components, and sub-components whose duration exceeds one year. For each warranty listed, indicate the applicable specification section, duration, start date, end date, and the point of contact for warranty fulfillment. Also, list or reference the specific operation and maintenance procedures that must be performed to keep the warranty valid. Provide copies of warranties required by Section 01 78 00 CLOSEOUT SUBMITTALS.

1.6.5.7 Personnel Training Requirements

Provide information available from the manufacturers that is needed for use in training designated personnel to properly operate and maintain the equipment and systems.

1.6.5.8 Testing Equipment and Special Tool Information

Include information on test equipment required to perform specified tests and on special tools needed for the operation, maintenance, and repair of components. Provide final set points.

1.6.5.9 Testing and Performance Data

Include completed prefunctional checklists, functional performance test forms, and monitoring reports. Include recommended schedule for retesting and blank test forms. Provide final set points.

1.6.5.10 Field Test Reports

Provide a copy of Field Test Reports (SD-06) submittals documented with the required approval.

1.6.5.11 Contractor Information

Provide a list that includes the name, address, and telephone number of the General Contractor and each Subcontractor who installed the product or equipment, or system. For each item, also provide the name address and telephone number of the manufacturer's representative and service organization that can provide replacements most convenient to the project site. Provide the name, address, and telephone number of the product, equipment, and system manufacturers.

1.7 SCHEDULE OF OPERATION AND MAINTENANCE DATA PACKAGES

NOTE: The type of O&M data needed for any product, system, or piece of equipment depends upon the complexity of that item. If not, specify the appropriate Data Package number in the technical section using the Data Package Number from the choices 1 through 5 below.

Data Package 1 is typically used for architectural items requiring simple but specific maintenance and replacement; for example, acoustical ceiling, floor tile or carpeting system.

Data Package 2 is used for an item that is less simple; for example, an item having a motor and some sequence of operation such as a refrigerated drinking fountain.

Data Package 3 is used for a complex piece of equipment, having a specific troubleshooting sequence, but one which does not require an operator on watch; for example, HVAC temperature controls.

Data Package 4 is used for an extremely complex piece of equipment, having an extensive sequence of operation, a complex troubleshooting sequence and one requiring frequent operator attention; at least for start-up and shut-down. Examples of this case would be small boilers and small diesel generator sets.

Data Package 5 is used for electrical equipment, components or systems on which, wiring and control diagrams are needed for operation, maintenance or repair. Examples of this case are 400 Hz frequency converters, annunciator panels and cathodic protection systems.

Provide the O&M data packages specified in individual technical sections. The information required in each type of data package follows:

1.7.1 Data Package 1

- a. Safety precautions and hazards
- b. Cleaning recommendations
- c. Maintenance and repair procedures
- d. Warranty information
- e. Extended warranty information
- f. Contractor information
- g. Spare parts and supply list

1.7.2 Data Package 2

- a. Safety precautions and hazards
- b. Normal operations
- c. Environmental conditions
- d. Lubrication data
- e. Preventive maintenance plan, schedule, and procedures
- f. Cleaning recommendations
- g. Maintenance and repair procedures
- h. Removal and replacement instructions
- i. Spare parts and supply list
- j. Parts identification
- k. Warranty information
- l. Extended warranty information
- m. Contractor information

1.7.3 Data Package 3

- a. Safety precautions and hazards

- b. Operator prestart
 - c. Startup, shutdown, and post-shutdown procedures
 - d. Normal operations
 - e. Emergency operations
 - f. Environmental conditions
 - g. Operating log
 - h. Lubrication data
 - i. Preventive maintenance plan, schedule, and procedures
 - j. Cleaning recommendations
 - k. Troubleshooting guides and diagnostic techniques
 - l. Wiring diagrams and control diagrams
 - m. Maintenance and repair procedures
 - n. Removal and replacement instructions
 - o. Spare parts and supply list
 - p. Product submittal data
 - q. O&M submittal data
 - r. Parts identification
 - s. Warranty information
 - t. Extended warranty information
 - u. Testing equipment and special tool information
 - v. Testing and performance data
 - w. Contractor information
 - x. Field test reports
- 1.7.4 Data Package 4
- a. Safety precautions and hazards
 - b. Operator prestart
 - c. Startup, shutdown, and post-shutdown procedures
 - d. Normal operations
 - e. Emergency operations

- f. Operator service requirements
- g. Environmental conditions
- h. Operating log
- i. Lubrication data
- j. Preventive maintenance plan, schedule, and procedures
- k. Cleaning recommendations
- l. Troubleshooting guides and diagnostic techniques
- m. Wiring diagrams and control diagrams
- n. Repair procedures
- o. Removal and replacement instructions
- p. Spare parts and supply list
- q. Repair work-hours
- r. Product submittal data
- s. O&M submittal data
- t. Parts identification
- u. Warranty information
- v. Extended warranty information
- w. Personnel training requirements
- x. Testing equipment and special tool information
- y. Testing and performance data
- z. Contractor information
- aa. Field test reports

1.7.5 Data Package 5

- a. Safety precautions and hazards
- b. Operator prestart
- c. Start-up, shutdown, and post-shutdown procedures
- d. Normal operations
- e. Environmental conditions
- f. Preventive maintenance plan, schedule, and procedures
- g. Troubleshooting guides and diagnostic techniques

- h. Wiring and control diagrams
- i. Maintenance and repair procedures
- j. Removal and replacement instructions
- k. Spare parts and supply list
- l. Product submittal data
- m. Manufacturer's instructions
- n. O&M submittal data
- o. Parts identification
- p. Testing equipment and special tool information
- q. Warranty information
- r. Extended warranty information
- s. Testing and performance data
- t. Contractor information
- u. Field test reports
- [v. Additional requirements for HVAC control systems

]PART 2 PRODUCTS

Not Used

PART 3 EXECUTION

3.1 TRAINING

NOTE: Use bracketed, tailored option for Facility Management Specialist for Navy projects only.

NOTE: For Navy projects only, in fourth sentence, choose the second bracketed option for eOMSI Manual if Section 01 78 24.00 20 is used in the project otherwise, choose the first bracketed item. The second bracketed item is tailored for NAVY use only.

Prior to acceptance of the facility by the Contracting Officer for Beneficial Occupancy, provide comprehensive training for the systems and equipment specified in the technical specifications. The training must be targeted for the [Facilities Management Specialist,]building maintenance personnel, and applicable building occupants. Instructors must be well-versed in the particular systems that they are presenting. Address

aspects of the [Operation and Maintenance Manual submitted in accordance with Section 01 78 00 CLOSEOUT SUBMITTALS.][eOMSI Manual, as submitted in Section 01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND MAINTENANCE SUPPORT INFORMATION (eOMSI)]. Training must include classroom or field lectures based on the system operating requirements. The location of classroom training requires approval by the Contracting Officer.

3.1.1.1 Training Plan

NOTE: Choose the Commissioning Authority (CxA) to oversee and approve the training plan if the project requires a CxA. If a CxA is not required, choose the bracketed option for the QC to oversee and approve the training plan and schedule.

This paragraph contains tailoring for Commissioning Authority.

Submit a written training plan to the Contracting Officer for approval at least 60 calendar days prior to the scheduled training. Training plan must be approved by the [Quality Control Manager (QC)][Commissioning Authority (CxA)] prior to forwarding to the Contracting Officer. Also, coordinate the training schedule with the Contracting Officer and [QC][CxA]. Include within the plan the following elements:

- a. Equipment included in training
- b. Intended audience
- c. Location of training
- d. Dates of training
- e. Objectives
- f. Outline of the information to be presented and subjects covered including description
- g. Start and finish times and duration of training on each subject
- h. Methods (e.g. classroom lecture, video, site walk-through, actual operational demonstrations, written handouts)
- i. Instructor names and instructor qualifications for each subject
- j. List of texts and other materials to be furnished by the Contractor that are required to support training
- k. Description of proposed software to be used for video recording of training sessions.

3.1.1.2 Training Content

NOTE: Choose the Commissioning Authority (CxA) to oversee and approve the training content if the project requires a CxA. If a CxA is not required,

choose the bracketed option for the QC to oversee and approve the training content. The CxA option is tailored.

NOTE: Use the bracketed option if 01 78 24.00 20 is used in the project, otherwise, delete. This option is tailored for NAVY use.

The core of this training must be based on manufacturer's recommendations and the operation and maintenance information. The [QC][CxA] is responsible for overseeing and approving the content and adequacy of the training. [Provide a brief summary of the FACILITY INFORMATION manual, and a more detailed presentation of the PRODUCT AND DRAWING MANUAL, specified in Section 01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND MAINTENANCE SUPPORT INFORMATION (eOMSI).]Spend 95 percent of the instruction time during the presentation on the OPERATION AND MAINTENANCE DATA. Include the following for each system training presentation:

- a. Start-up, normal operation, shutdown, unoccupied operation, seasonal changeover, manual operation, controls set-up and programming, troubleshooting, and alarms.
- b. Relevant health and safety issues.
- c. Discussion of how the feature or system is environmentally responsive. Advise adjustments and optimizing methods for energy conservation.
- d. Design intent.
- e. Use of O&M Manual Files.
- f. Review of control drawings and schematics.
- g. Interactions with other systems.
- h. Special maintenance and replacement sources.
- i. Tenant interaction issues.

3.1.3 Training Outline

NOTE: Use the second bracketed item if Section 01 78 24.00 20 is used in the project, and delete the first. Otherwise use the first bracketed item, and delete the second. The second bracketed item is tailored for NAVY use.

NOTE: This paragraph contains tailoring tags around eOMSI Facility Data Workbook which is specified in Section 01 78 24.00 20. Edit to include if specified in Section 01 78 24.00 20; otherwise, delete.

Provide the [Operation and Maintenance Manual Files (Bookmarked PDF)]
[eOMSI Manual files as specified in Section 01 78 24.00 20, FACILITY
ELECTRONIC OPERATION AND MAINTENANCE SUPPORT INFORMATION (eOMSI),]and a
written course outline listing the major and minor topics to be discussed
by the instructor on each day of the course to each trainee in the
course. Provide the course outline 14 calendar days prior to the training.

3.1.4 Training Video Recording

Record classroom training session(s) on video. Provide to the Contracting
Officer two copies of the training session(s) in DVD video recording
format. Capture within the recording, in video and audio, the
instructors' training presentations including question and answer periods
with the attendees. The recording camera(s) must be attended by a person
during the recording sessions to assure proper size of exhibits and
projections during the recording are visible and readable when viewed as
training.

3.1.5 Unresolved Questions from Attendees

If, at the end of the training course, there are questions from attendees
that remain unresolved, the instructor must send the answers, in writing,
to the Contracting Officer for transmittal to the attendees, and the
training video must be modified to include the appropriate clarifications.

3.1.6 Validation of Training Completion

Ensure that each attendee at each training session signs a class roster
daily to confirm Government participation in the training. At the
completion of training, submit a signed validation letter that includes a
sample record of training for reporting what systems were included in the
training, who provided the training, when and where the training was
performed, and copies of the signed class rosters. Provide two copies of
the validation to the Contracting Officer, and one copy to the Operation
and Maintenance Manual Preparer for inclusion into the Manual's
documentation.

3.1.7 Quality Control Coordination

NOTE: Choose the Commissioning Authority (CxA) for
QC coordination if the project requires a CxA. If a
CxA is not required, choose the bracketed option for
the QC to approve the training content.

For Navy, choose Section 01 45 00.00 20 QUALITY
CONTROL for Design-Bid-Build or Section 01 45 00.05
20 DESIGN AND CONSTRUCTION QUALITY CONTROL for
Design-Build.

Coordinate this training with the [QC][CxA] in accordance with [Section 01 45 00.00 10 QUALITY CONTROL][Section 01 45 00.00 20 QUALITY CONTROL][Section 01 45 00.00 40 QUALITY CONTROL][Section 01 45 00.05 20 DESIGN AND CONSTRUCTION QUALITY CONTROL FOR DESIGN-BUILD].

-- End of Section --