

**SERVICE ENTRANCE
AVAILABLE FAULT CURRENT**

Available Fault Current: _____ **Amperes**

Calculation Date: _____

Organization: _____

NOTES:

1. PROVIDE SELF-ADHESIVE VINYL LABEL TO AFFIX TO ELECTRICAL EQUIPMENT TO PROVIDE MAXIMUM AVAILABLE FAULT CURRENT AT THE SERVICE ENTRANCE.
2. THE LABEL FORMAT AND TEXT SHALL BE IN ACCORDANCE WITH THE FIGURE.
3. THE LABEL SHALL BE LOCATED ON THE EQUIPMENT TO BE CLEARLY VISIBLE TO QUALIFIED PERSONS BEFORE EXAMINATION, ADJUSTMENT, SERVICING, OR MAINTENANCE OF THE EQUIPMENT.
4. THE SIZE OF THE LABEL SHALL BE MINIMUM:

<u>EQUIPMENT TYPE</u>	<u>HEIGHT</u>	<u>WIDTH</u>
INDOOR	2"	3"
OUTDOOR	2"	3"

5. A DOWNLOADABLE WINDOWS METAFILE IS AVAILABLE ON THE WHOLE BUILDING DESIGN GUIDE WEBSITE ([WWW.WBDG.ORG](http://www.wbdg.org)) FOR USE IN A LABEL MAKING MACHINE.
 - A. THE FILE IS LOCATED ON THE "NAVFAC CADD DETAILS" PAGE. TO NAVIGATE TO THIS LOCATION, FOLLOW: [HOME](#) > [DOCUMENTS & REFERENCES](#) > [CCB](#) > [CADD LIBRARY](#) > [NAVFAC CADD RESOURCES](#) > NAVFAC CADD DETAILS.
 - B. ALTERNATIVELY, TYPE IN THE FOLLOWING ADDRESS IN INTERNET EXPLORER:
[HTTP://WWW.WBDG.ORG/CCB/BROWSE_CAT.PHP?C=232](http://www.wbdg.org/ccb/browse_cat.php?c=232)

SERVICE ENTRANCE AVAILABLE FAULT CURRENT LABEL